

产品认证证书

II型自愿认证

证书编号: CQC2016010301849906

发证日期: 2020年10月28日

有效期至: 2031年04月26日

委托人名称 湖北金顿电气有限公司
及注册地址 襄阳市高新区关羽路99号(湖北铁能电气集团有限公司院内)

制造商名称 湖北金顿电气有限公司
及注册地址 襄阳市高新区关羽路99号(湖北铁能电气集团有限公司院内)

生产企业名称 湖北金顿电气有限公司
及生产地址 襄阳市高新区关羽路99号

产品名称和系列、规格、型号 低压固定分闸柜(低压成套开关设备)
GDF 主母线InA=4000A~1600A,Icw=80kA;配电母线Inc=1000A~400A,Icw=30kA;Ue=380V、400V,Ui=690V,50Hz,IP41、IP40

产品标准和技术要求 GB/T 7251.12-2013

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人: 主任:

陈昕 陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0035653

PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2016010301849906

Valid from: Oct.28,2020

Valid until: Apr.26,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Hubei gold Dayton Electric Co., Ltd.
No. 99 Guan Yu Road, Xiangyang hi tech Development Zone (Hubei Railway Electric Group Co., Ltd.)

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Hubei gold Dayton Electric Co., Ltd.
No. 99 Guan Yu Road, Xiangyang hi tech Development Zone (Hubei Railway Electric Group Co., Ltd.)

NAME AND LOCATION OF THE FACTORY Hubei gold Dayton Electric Co., Ltd.
No. 99 Guan Yu Road, Xiangyang hi tech Development Zone (Hubei Railway Electric Group Co., Ltd.)

PRODUCT NAME, MODEL AND SPECIFICATION Low-voltage Switchgear Assemblies
GDF 主母线InA=4000A~1600A,Icw=80kA;配电母线InC=1000A~400A,Icw=30kA,Ue=380V, 400V,Ui=690V;50Hz;IP41, IP40

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 7251.12-2013

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

PRESIDENT:

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0035653

产品认证证书

II型自愿认证

证书编号: CQC2016010301849911

发证日期: 2020年10月28日

有效期至: 2031年04月26日

委托人名称及注册地址 湖北金顿电气有限公司
襄阳市高新区关羽路99号(湖北铁能电气集团有限公司院内)

制造商名称及注册地址 湖北金顿电气有限公司
襄阳市高新区关羽路99号(湖北铁能电气集团有限公司院内)

生产企业名称及生产地址 湖北金顿电气有限公司
襄阳市高新区关羽路99号

产品名称和系列、规格、型号 低压固定分闸柜(低压成套开关设备)
GDF 主母线:InA=1600A~400A,Icw=30kA,配电母线:Inc=800A~400A,Icw=30kA,Ue=380V、400V,Ui=690V,50Hz,IP41、IP40

产品标准和技术要求 GB/T 7251.12-2013

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查询证书信息



授权签字人: 主任:

陈昕 陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路198号9区 100070

电话: +86 10 63886666

C(2) 0035654

PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2016010301849911

Valid from: Oct.28,2020

Valid until: Apr.26,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Hubei gold Dayton Electric Co., Ltd.
No. 99 Guan Yu Road, Xiangyang hi tech Development Zone (Hubei Railway Electric Group Co., Ltd.)

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Hubei gold Dayton Electric Co., Ltd.
No. 99 Guan Yu Road, Xiangyang hi tech Development Zone (Hubei Railway Electric Group Co., Ltd.)

NAME AND LOCATION OF THE FACTORY Hubei gold Dayton Electric Co., Ltd.
No. 99 Guan Yu Road, Xiangyang hi tech Development Zone (Hubei Railway Electric Group Co., Ltd.)

PRODUCT NAME, MODEL AND SPECIFICATION Low-voltage Switchgear Assemblies
GDF 主母线InA=1600A~400A,Icw=30kA 配电母线InC=800A~400A,Icw=30kA,Ue=380V, 400V,Ui=690V,50Hz,IP41, IP40

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 7251.12-2013

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

陈昕

PRESIDENT:

陆楠

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0035654