

# 产品认证证书

## II型自愿认证

证书编号: CQC2012010301538812

发证日期: 2021年11月05日

有效期至: 2031年11月05日

**委托人名称** 湖北金顿电气有限公司  
**及注册地址** 襄阳市高新区关羽路99号(湖北铁能电气集团有限公司院内)

**制造商名称** 湖北金顿电气有限公司  
**及注册地址** 襄阳市高新区关羽路99号(湖北铁能电气集团有限公司院内)

**生产企业名称** 湖北金顿电气有限公司  
**及生产地址** 襄阳市高新区关羽路99号

**产品名称和系列、规格、型号** 电容补偿柜(低压成套无功功率补偿装置)  
JRPC2 InA=393A~66A, Icw=15kA; Ue=380V, Ui=660V; 360kvar~60kvar, 单相、三相结合补偿; 50Hz; IP30, 户内型; 控制投切电容器的元件类型: 复合开关

**产品标准和技术要求** GB/T 15576-2020

**认证模式** 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特此认证。

本证书为变更证书, 证书首次颁发日期: 2020年04月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 ([www.cnca.gov.cn](http://www.cnca.gov.cn)) 查验证书信息



授权签字人

签发

张崇三

谢肇煦

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0105500

# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2012010301538812

Valid from: Nov.05,2021

Valid until:Nov.05,2031

<b>NAME AND REGISTERED ADDRESS OF THE APPLICANT</b>	Hubei gold Dayton Electric Co., Ltd. No. 99 Guan Yu Road, Xiangyang hi-tech Development Zone (Hubei Railway Electric Group Co., Ltd.)
<b>NAME AND REGISTERED ADDRESS OF THE MANUFACTURER</b>	Hubei gold Dayton Electric Co., Ltd. No. 99 Guan Yu Road, Xiangyang hi-tech Development Zone (Hubei Railway Electric Group Co., Ltd.)
<b>NAME AND LOCATION OF THE FACTORY</b>	Hubei gold Dayton Electric Co., Ltd. No. 99 Guan Yu Road, Xiangyang hi-tech Development Zone (Hubei Railway Electric Group Co., Ltd.)
<b>PRODUCT NAME, MODEL AND SPECIFICATION</b>	Low-voltage reactive power compensation assemblies JRPC2 10A-393A-66A, Icw=15kA, Ue=380V, Ij=660V, 360kvar-60kvar, 单相、三相组合补偿, 50Hz, IP30, 户内型, 控制投切电容器的元件类型: 组合开关
<b>THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS</b>	GB/T 15576-2020
<b>TYPE OF CERTIFICATION SCHEMES</b>	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Apr.09,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGN BY

李崇三

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Mansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666

C(2) 0105500